



## **TUBEAXIAL FANS**

Paint Spray Booth Exhaust & Supply Fans

CATALOG 159 March 2013

## **Paint Spray Booth Fans**





6-Bladed BSA Propeller



Aerodynamic belt tube with standard access door



Maintenance-free bearing assembly



The Aerovent Model BTABD is a belt driven tubeaxial fan that is designed specifically for reliable and cost effective air movement in paint spray booth applications. Model BTABD exhaust fans are designed for applications requiring either a horizontal or a vertical airflow direction.

#### **Sizes and Performance**

- Arrangement 9 belt driven (motor out of airstream)
- · Available in sizes from 12" to 42" diameter
- Capacity to 36,131 CFM
- Static pressures to 1.25" w.g.

#### **Construction Features**

- Aluminum (non-ferrous) spark resistant propeller dynamically balanced for quiet, vibration-free operation
- Continuously welded, heavy-gauge, corrosion resistant, powder coated steel housing with prepunched inlet and outlet flanges
- · OSHA belt guards are standard
- Non-relubricable "sealed for life" ball bearings in mono-block housing to ensure reliable bearing performance
- Drive system isolated from airstream
- · Designed for continuous duty

#### Housing

Housings are heavy-gauge, hot-rolled steel construction, continuously welded and ground smooth to assure efficient airflow through the housing. Inlet and outlet flanges are integrally rolled and punched to allow attachment to ductwork or accessories as necessary.

#### **Drive Isolated from Airstream**

The shaft and bearing assembly is mounted within an inner cylinder isolated from the airstream. The v-belt drive assembly is enclosed in an aerodynamically designed belt tube which maximizes fan efficiency, minimizes air blockage and reduces noise generation. An access door on the belt tube is standard.

#### Propeller

- Die cast aluminum construction
- · Unique BackSwept profile with airfoil cross section
- · Adjustable pitch blades with factory set blade angles
- Uses split taper lock bushing for superior holding power on shaft
- · Generates low wake turbulence for low noise emission

#### Support Legs

Support legs are available for standard platform or floor mounting. The support legs are bolted to the inlet and outlet flange.

#### **Inlet and Outlet Guards**

Inlet and outlet guards are offered to protect personnel from the moving parts. Recommended for use when no ductwork is attached to the inlet and/ or outlet. Guards are removable for routine inspection and cleaning of the propeller.

#### **Inlet Bell Option**

An inlet bell is recommended on the inlet side of the fan to minimize entrance losses for installations where the fan inlet is not attached to a duct system. The inlet bell is bolted to the inlet flange.

# Accessories



Support Legs



Inlet/Outlet Guard

### **Optional Mounting Arrangements**


**Horizontal Ceiling Mounted** 

(view from outlet)


Following are optional mounting arrangements for the Model BTABD fans.



(view from outlet)




Standard (Std)



Top


Opposite Standard, (Optional Std) Requires F-2 Motor



Bottom (A11)

Тор (А12)

Vertical Mounted (view from side)



Vertical Down (VDB) (No mounting brackets) AIRFLOW

Vertical Down (VUB) (No mounting brackets) To identify a specific fan for ordering or engineering specification, it is necessary to show the complete catalog number as shown at the right. All performance data is available in curve form upon request.

All capacities shown in the performance tables that follow are for standard air conditions: 70°F at sea level (0.075 lbs./cu.ft. air density).

The tables show a representative sample of the wide range of propellers available.

#### **Model Nomenclature**

BTABD - <u>16 B 1 05 24</u>
Prop. Diameter
Blade Design
Hub Size
No. of Blades
Blade Angle

#### BTABD | Size 12

CATALOO	G NUM	BER						CUB	IC FEE	T PE	R MIN	UTE 8	HOR	SEPO	WER /	AT ST	ATIC F	RESS	URE				
FAN	RPM	ць	0"	SP	1/8"	SP	1/4'	SP	3/8"	SP	1/2"	SP	5/8'	SP	3/4'	' SP	7/8	SP	1" \$	SP	<b>1</b> 1⁄%"	SP	1¼" SP
SIZE	RPIN	ΠP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM BHP
12B10521	2375	1/4	1295	0.20	1240	0.21	1171	0.22	1102	0.22	1010	0.23	900	0.24	730	0.24							
12B10521	2745	1/2	1500	0.31	1452	0.32	1394	0.33	1336	0.34	1273	0.35	1200	0.36	1107	0.37							
12B10521	3576	1	1953	0.67	1923	0.69	1879	0.71	1835	0.72	1788	0.74	0.75	1745	1700	0.76	1647	0.77					

#### BTABD | Size 14

CATALO	G NUM	BER						CUB	IC FEE	T PE	R MIN	UTE 8	HOR	SEPO	WER /	AT ST	ATIC F	RESS	URE					
FAN	RPM	ць	0"	SP	1/8"	SP	1/4"	SP	3/8'	SP	1/2"	SP	5/8"	SP	3/4'	' SP	7/8'	' SP	1" S	SP	<b>1</b> 1⁄8"	SP	11⁄4" S	Р
SIZE	RPIN	ΠP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM I	BHP	CFM	BHP	CFM B	ΗP
14B10532	2036	1/2	2478	0.45	2375	0.47	2255	0.48	2130	0.49	1930	0.50	1691	0.49										
14B10532	2258	3/4	2751	0.62	2659	0.64	2555	0.65	2447	0.67	2320	0.68	2122	0.69	1906	0.68								
14B10532	2463	1	2991	0.80	2916	0.82	2819	0.85	2723	0.86	2619	0.87	2489	0.88	2300	0.88	2104	0.88						

#### BTABD | Size 16

CATALOO	G NUM	BER						CUB	IC FEE	T PE	R MIN	UTE 8	HOR	SEPO	WER /	AT ST	ATIC F	RESS	URE					
FAN	RPM	цв	0"	SP	1/8"	SP	1/4"	' SP	3/8'	SP	1/2'	SP	5/8"	SP	3/4'	' SP	7/8"	SP	1":	SP	<b>1</b> 1⁄8"	SP	1¼"	SP
SIZE	RPM	<b>n</b> P	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
16B10524	1890	1/2	2887	0.47	2769	0.42	2631	0.44	2485	0.46	2300	0.48	2071	0.48	1815	0.48								
16B10524	2145	3/4	3272	0.60	3173	0.62	3059	0.64	2934	0.69	2800	0.50	2637	0.69	2440	0.75	2237	0.71						
16B10524	2429	1	3709	0.86	3620	0.88	3516	0.91	3412	0.94	3303	0.95	3183	0.97	3050	1.00	2887	1.01	2705	1.02	2523	1.02		

#### BTABD | Size 18

CATALOO	G NUM	BER						CUB	IC FEE	T PE	R MIN	UTE 8	HOR	SEPO	WER /	AT ST	ATIC F	RESS	URE					
FAN	RPM	ць	0"	SP	1/8"	SP	1/4"	SP	3/8'	SP	1/2"	SP	5/8'	SP	3/4'	' SP	7/8'	' SP	1"	SP	<b>1</b> <sup>1</sup> /8"	SP	<b>1</b> 1⁄4"	' SP
SIZE	RPIN	ΠP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
18B10525	1496	1/2	3309	0.33	3142	0.35	2918	0.37	2656	0.38	2320	0.39												
18B10525	1877	3/4	4125	0.66	4031	0.68	3867	0.71	3694	0.73	3500	0.75	3263	0.77	2980	0.77	2698	0.77						
18B10525	2064	1	4572	0.88	4463	0.90	4307	0.93	4166	0.95	4000	0.98	3815	0.99	3597	1.01	3355	1.03	3090	1.03	2754	1.01		
18B10525	2237	<b>1</b> ½	4939	1.12	4861	1.14	4728	1.17	4588	1.20	4440	1.22	4283	1.25	4104	1.28	3909	1.30	3683	1.31	3456	1.31	3200	1.25
18B10525	2566	2	5684	1.69	5618	1.71	5501	1.75	5385	1.78	5260	1.82	5135	1.85	5000	1.87	4852	1.90	4686	1.93	4519	1.95	4319	1.97

#### BTABD | Size 24

4

CATALO	G NUM	BER						CUB	IC FEE	T PE	R MIN	UTE 8	HOR	SEPO	WER /	AT ST	ATIC F	RESS	SURE					
FAN	DDM	ць	0"	SP	1/8"	SP	1/4"	SP	3/8'	SP	1/2'	SP	5/8"	SP	3/4'	SP	7/8'	SP	1"	SP	<b>1</b> 1⁄/8"	SP	<b>1</b> ¼'	' SP
SIZE	RPM	HP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
24B30618	1427	3/4	6393	0.61	6163	0.69	5878	0.77	5574	0.85														
24B30618	1565	1	7012	0.80	6804	0.89	6551	0.99	6505	1.07	6000	1.15	5701	1.20										
24B30618	1719	<b>1</b> ½	7701	1.06	7514	1.16	7291	1.27	7046	1.37	6800	1.46	6542	1.53	6261	1.59	5969	1.63	5653	1.66				
24B30618	1856	2	8321	1.34	8146	1.44	7935	1.56	7724	1.67	7500	1.77	7256	1.86	7010	1.94	6753	2.00	6472	2.05	6203	2.08	5910	2.10
24B30618	2119	3	9488	2.00	9363	2.10	9176	2.24	8988	2.38	8785	2.51	8598	2.62	8400	2.72	8193	2.81	7958	2.90	7740	2.97	7521	3.03

Performance shown is for installation type D: Ducted inlet, ducted outlet. Power ratings (BHP) do not include drive losses. Performance ratings do not include the effects of appurtenances in the airstream.

#### BTABD | Size 30

CATALOG	NUM	BER						CUI	BIC FE	ET PE	R MIN	UTE 8	HOR	SEPO	WER A	T ST	ATIC F	RESS	URE					
FAN	DDM		0" :	SP	1/8"	SP	1/4"	SP	3/8"	SP	1/2"	SP	5/8"	SP	3/4"	SP	7/8"	SP	1"	SP	<b>1</b> 1⁄8"	SP	<b>1</b> ¼"	SP
SIZE	RPM	HP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
30B30618	1060	1	9224	0.68	8737	0.79	8220	0.89	7639	0.97	7000	1.01	6290	1.03	5537	1.02								
30B30618	1218	<b>1</b> ½	10588	1.03	10180	1.16	9741	1.29	9271	1.39	8750	1.47	8204	1.53	7608	1.56	6965	1.56	6337	1.55				
30B30618	1337	2	11610	1.37	11256	1.51	10861	1.65	10445	1.78	10000	1.88	9508	1.97	9009	2.02	8468	2.05	7886	2.06	7324	2.05	6741	2.04
30B30618	1538	3	13316	2.11	13066	2.24	12713	2.42	12359	2.57	12000	2.71	11600	2.83	11194	2.94	10778	3.02	10341	3.08	9862	3.12	9384	3.14
30B30618	1852	5	16104	3.63	15870	3.82	15589	4.03	15308	4.23	15000	4.42	14700	4.6	14372	4.77	14068	4.91	13740	5.04	13389	5.16	13038	5.26

#### BTABD | Size 34

CATALOG	NUM	BER						CUI	BIC FE	ET PE	R MIN	UTE 8	HORS	SEPO	WER A	T ST	ATIC P	RESS	URE					
FAN	RPM	ць	0" \$	SP	1/8"	SP	1/4"	SP	3/8"	SP	1/2"	SP	5/8"	SP	3/4"	SP	7/8"	SP	1"	SP	<b>1</b> <sup>1</sup> /8"	SP	11⁄4"	SP
SIZE	RPIN	<b>HP</b>	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
34B30420	1190	2	15106	1.63	14447	1.75	13671	1.85	12824	1.92	12000	1.96	11035	1.97	10094	1.96	9176	1.94						
34B30420	1382	3	17540	2.55	17009	2.68	16322	2.83	15698	2.92	15000	3.00	14231	3.06	13420	3.08	12640	3.08	11797	3.06	10986	3.04		
34B30420	1621	5	20567	4.12	20130	4.27	19599	4.44	19069	4.58	18500	4.70	17883	4.81	17259	4.89	16635	4.94	15948	4.97	15230	4.98	14512	4.97

#### BTABD | Size 36

CATALOG	NUM	BER				С	UBIC FE	ET P	ER MIN	UTE 8	HORS	SEPO	WER A	T ST/	ATIC F	RESS	URE					
FAN	RPM	шъ	0" SP	1/8"	SP	1/4" SP	3/8	' SP	1/2"	SP	5/8"	SP	3/4"	SP	7/8'	' SP	1"	SP	<b>1</b> 1⁄8"	SP	1¼" S	SP
SIZE	RPIN	ΠP	CFM BH	CFM	BHP	CFM BH	P CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM E	BHP
36B30420	1118	2	16736 1.7	2 15964	1.84	15051 1.9	4 1406	3 2.01	13000	2.04	11891	2.03	10767	2.02								
36B30420	1277	3	19137 2.5	5 18478	2.70	17694 2.8	3 16878	3 2.93	16000	3.00	15059	3.03	14086	3.04	13114	3.02	12110	3.00				
36B30420	1511	5	22684 4.2	3 22101	4.41	21446 4.5	8 2079	1 4.72	20100	4.93	19371	4.93	18606	4.99	17841	5.03	17004	5.04	16166	5.02	15293 5	5.00


#### BTABD | Size 42

CATALOG		BER						CU	BIC FE	ET P	ER MI	NUTE	& HOP	RSEP	OWER	AT ST	ATIC	PRES	SURE					
FAN	RPM	шв	0" :	SP	1/8"	SP	1/4"	SP	3/8"	SP	1/2"	SP	5/8"	SP	3/4"	SP	7/8"	SP	1" :	SP	<b>1</b> 1⁄8"	SP	<b>1</b> 1⁄4"	SP
SIZE	RPM	ΠP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP	CFM	BHP
42B30420	1032	3	23376	2.43	22190	2.59	20817	2.71	19506	2.77	18000	2.79	16447	2.78	14918	2.75								
42B30420	1246	5	28213	4.29	27256	4.48	26216	4.65	25134	4.77	24000	4.86	22804	4.91	21514	4.92	20224	4.90	18934	4.87	17727	4.84		
42B30420	1359	7½	30793	5.56	29909	5.77	28973	5.96	27984	6.12	27000	6.24	25904	6.33	24811	6.37	23667	6.39	22419	6.37	21274	6.34	20078	6.30
42B30420	1636	10	36131	9.01	35399	9.26	34614	9.49	33830	9.70	33000	9.88	32105	10.04	31216	10.16	30327	10.25	29386	10.30	28392	10.33	27399	10.34

Performance shown is for installation type D: Ducted inlet, ducted outlet. Power ratings (BHP) do not include drive losses.

Performance ratings do not include the effects of appurtenances in the airstream.





SIZE	А	В	С	D	E	F	MAX. MTR FRAME
12	12.25	13.88	14.88	12.00	8	.44	145T
14	14.25	15.88	16.88	12.00	8	.44	145T
16	16.25	17.88	19.00	12.00	8	.44	145T
18	18.25	19.88	21.00	12.00	8	.44	145T
24	24.25	25.88	27.13	15.50	8	.56	184T
30	30.38	31.88	33.25	15.50	8	.56	184T
34	34.38	35.75	37.38	15.50	8	.56	184T
36	36.38	37.88	39.38	15.50	16	.56	184T
42	42.50	44.13	45.50	15.50	16	.56	215T

Dimensions shown are in inches unless otherwise indicated. Dimensions are not to be used for construction.

R33867

## Model BTABD | Arrangement 9 | Belt Driven

Fans, where indicated on drawings and schedules, shall be Model BTABD, Arrangement 9, V-belt driven, axial flow type as manufactured by Aerovent, Minneapolis, Minnesota, and shall be of the size and capacity as indicated in the fan schedules. Model BTABD fans have been tested in an AMCA registered laboratory in accordance with AMCA 210 and AMCA 300 test codes for both air and sound. In addition each unit shall be factory run tested and final trim balanced prior to shipment.

**CONSTRUCTION** — Fan casings shall be welded of ASTM A-1011 low carbon, commercial quality 12-gauge hot rolled steel in sizes through 20" diameter, 10-gauge hot rolled steel from 24" diameter through 28" diameter, and 7-gauge hot rolled steel on sizes greater than 30" in diameter. Inlet and outlet flanges shall be integrally rolled mechanically from fan casing sheet steel to insure concentricity and alignment. Accuracy and uniformity of the fan casing shall be insured through the use of welding jigs and fixtures. The motor base plate shall be fabricated of minimum  $\frac{3}{16}$ " steel plate and supports welded to the exterior of the fan casing.

**PROPELLERS** — Propellers shall be constructed of spark resistant (non-ferrous) die cast aluminum hubs and blades. Fan blade pitch angle shall be preset at the factory. Propellers shall be secured to the fan shaft with a taper lock bushing.

**SHAFT & BEARINGS** — All fans shall be supplied with a shaft of AISI C-1045 steel material that has been properly turned, ground, and polished for accuracy. The shaft shall be supported by a matched set of non-relubricable bearings that are housed in a cast aluminum monoblock. All fan bearings are to have an L-10 minimum life as defined by AFBMA of at least 60,000 hours.

**DRIVES** — Fan drives shall include cast iron sheaves and non-static conducting belts. Sheaves and belts are isolated from the airstream. Fans equipped with motors up to and including five horsepower will be furnished with a variable pitch type drive sheave to allow for minor speed adjustment of the fan propeller during system balance. Fans equipped with larger motors will be furnished with a fixed drive sheave. A belt guard is to be provided to afford personnel safety and general traffic protection.

**MOTORS** — Fan motors shall be manufactured in accordance with current applicable standards of IEEE and NEMA. They shall be foot-mounted, NEMA standard frame, TEFC or ODP, continuous duty, ball bearing with class "B" insulation. Motors are located out of the airstream.

**BALANCING** — The propeller assembly shall be statically and dynamically balanced in accordance with ANSI/ AMCA 204-05 "Balance Quality and Vibration Levels for Fans" to Fan Application Category BV-3, Balance Quality Grade G6.3. In addition, belt driven fan propellers shall be balanced on the fan shaft after final assembly in the fan casing, in the manufacturing facility to the following peak velocity values, filter-in, at the fan test speed:

Fan Application Category	Rigidly Mounted (In/Sec)	Flexibly Mounted (In/Sec)
BV-3	0.15	0.20

Final test room vibration levels in the axial, vertical, and horizontal planes shall be recorded and a written copy shall be available upon request.

**FINISH** — After fabrication, the fan housing shall be cleaned with a three-stage wash system and powder coated inside and out with a durable polyester coating.



©2013-2019 Aerovent, Minneapolis, MN. All rights reserved. Catalog illustrations cover the general appearance of Aerovent products at the time of publication and we reserve the right to make changes in design and construction at any time without notice. PROPELLER FANS | TUBEAXIAL & VANEAXIAL FANS | CENTRIFUGAL FANS & BLOWERS | ROOF VENTILATORS INDUSTRIAL AIR HANDLERS | AIR MAKE-UP | FIBERGLASS FANS | CUSTOM FANS





A Twin City Fan Company

WWW.AEROVENT.COM